

**Daikin One+ Thermostat Commissioning Menu Outline for Mini/multi-split (S21) equipment, v2.0.2 software**

Level 1	Level 2	Level 3	Level 4	Level 5	Default	Display only?	Conditions	
welcome	english	(radio buttons)			english			
	spanish							
	french							
	use large font	(checkbox)			(disabled)			
	continue							
equipment type	unitary	(radio buttons)			unitary			
	single/multi-split (S21)							
	VRV, SkyAir, single/multi-split (P1/P2)							
	continue							
setup	begin setup	(to smart thermostat setup with 5 main steps below)						
	factory reset							
	setup options	run dealer demo mode						
		run homeowner demo mode						
	learn more							
1. Communication	equipment type	unitary			unitary			
		mini/multi-split (S21)						
		VRV, SkyAir, mini/multi-split (P1/P2)						VRV will be supported in the future.
	home wifi	use wifi						
		networks	(list of available networks)	search again				Only appears when "use wifi" selected
		connected to internet					Yes	Only appears when connected to active wifi network.
connected to DaikinOne Cloud						Yes	Only appears if successfully connect to internet.	
2. Personalization	language	english francais espanol			english			
	date & time	(month, day, and year selection)			build date		set automatically when connect to WiFi.	
		(hour, minute, and am/pm selection)				disabled		set automatically when connect to WiFi.
		use 24-hour format						
	time zone	(list of time zones)			Pacific		set automatically when connect to mobile app.	
device name	main room upstairs downstairs hallway bedroom kitchen other (other name)	(text entry for other)			main room			
degree units	fahrenheit celsius				fahrenheit			
3. Equipment Setup	Indoor Unit: (model #)	Indoor Unit: (model #) (description based on model number)	(pick from list)	edit	(text entry)			
		Serial #:	(text entry)					
		unit type	wall-mount ceiling cassette single-flow cassette floor-mount				Maybe	Set automatically when model number selected from list. Default allows manual entry, also allowed if manually entered model number.
	Outdoor Unit: (model #)	Outdoor Unit: (model #) (description based on model number)	(pick from list)	edit	(text entry)			
		Serial #:	(text entry)					
	Standard filter	Number of filters	1, 2			1		
		Remove equipment	Do you want to remove this equipment?	Yes/No				
	Add Equipment	indoor air quality sensor						Can only add 1 of each type.
		HEPA filter						
		Filter box						
Indoor air quality sensor	Remove equipment	Do you want to remove this equipment?	Cancel	Continue				
	Number of filters	1, 2			0			
HEPA filter	Remove equipment	Do you want to remove this equipment?	Cancel	Continue				
	Number of filters	1, 2			0			
Filter box	Remove equipment	Do you want to remove this equipment?	Cancel	Continue				
4. System Optimization	Error History	(date and time of error) (code - Indoor Unit #) (error description) (minor error code)						
		Clear error history?	Cancel/Continue	Yes/No				
	Calibration	Temperature calibration	-7°F to 7°F in 1°F steps			0°F		
		Humidity calibration	-15% to 15% in 1% steps			0%		
	Status	Outdoor unit	EEV open degree (pulse)					Emura only
			outdoor air temp					Emura only
			heat exchanger temp					Emura only
			discharge temperature					Emura only
			liquid pipe temp					Emura only
			outdoor fan RPM					Emura only
power consumption							Emura only	
electric current							Emura only	
indoor suction temp							Emura only	
therm on/off							Emura only	
cool/heat	min/max setpoints	57°F to 90°F			57°F to 90°F		heating: 57 to 86 cooling: 64 to 90	
	deadband / overcool	Temperature setpoint	2°F to 9°F in 1°F steps		4°F			
		dead band:	0°F to 3°F in 1°F steps			0°F		
	Overcooling allowed to dehumidify:	1, 2, 3, 4°F (0.5, 1, 1.5, 2.0°C)			1°F			
	start timer diff							

5. Preferences		changeover settings	forced changeover diff	1, 2, 3, 4°F (0.5, 1, 1.5, 2.0°C)	1°F	Must be >= to start timer diff	
			changeover timer	0 to 60 min. in 15 min. steps	0	Timer started on heat-to-cool or cool-to-heat transition so doesn't change modes too quickly. Timer is ignored if forced changeover diff is reached.	
	<b>house settings</b>	House size	500 to 10,000 sf in 100 sf steps				
	<b>dealer information</b>	name	(text entry)				
		phone	(text entry)				
		email	(text entry)				
		website	(text entry)				
	<b>reminders</b>	message	(text entry)				
		Standard filter	off, 1, 2, 3, 4, 6, or 12		off		if added in "add equipment"
		HEPA filter	off, 1, 2, 3, 4, 6, or 12 months		off		if added in "add equipment"
		Filter box	off, 1, 2, 3, 4, 6, or 12		off		if added in "add equipment"
		service reminder	off, 3, 6, or 12 months		off		