

DAIKIN ONE+
SETTINGS MENU OUTLINE
(based on v2.1.16 software for unitary systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	
system mode	auto (cool & heat)					
	cool					
	heat					
	off					
	emergency heat					
display	language	english				
		español				
		française				
	degree units	fahrenheit				
		celsius				
	brightness	50 - 100% scale				
		night mode		night mode (check box)		
				from (time selection)		
				to (time selection)		
	screen cleaning		touch screen is disabled from screen cleaning (30s)			
	use large font (check box)					
	use sound (check box)					
	use light bar (check box)					
screen saver	off					
	blank screen					
	analog clock					
	digital clock					
lock	Enter a 4-digit PIN...		(number entry)			
schedule	schedule template	basic (awake/sleep)	preview template			
			(contents of template)			
		load template	cancel			
			continue			
		9 to 5 workweek	preview template			
			(contents of template)			
	load template	cancel				
		continue				
	early to rise	preview template				
		(contents of template)				
load template	cancel					
	continue					
manual adjustment overrides	until next event in schedule					
	for one hour					
	for two hours					
	for four hours					
	for eight hours					
away	use geofencing (checkbox)					
comfort	target humidity	25 - 75%	(10% Gap, 5% increments)			
air quality	circulate air	off				
		always on				
		on a schedule	fan schedule	set times	from (time)	
					to (time)	
	duration		for entire schedule			
			hourly for 5 minutes			
			hourly for 15 minutes			
		hourly for 30 minutes				
		hourly for 45 minutes				
fan speed	one clean	Off				
		On				
	low					
	medium					
	high					
utility demand response	program not connected					
	demand response	use demand response (checkbox)				
		When demand response signal is received:	offset temperature setpoints			
			use fixed temperature setpoints			
		response settings	setpoint offsets	Offset heat setpoints by this value: (-1°F to -7°F)		
				Offset cool setpoints by this value: (1°F to 7°F)		
			event setpoint limits	(50°F to 90°F)		
enable energy pricing (checkbox)						
price trigger (if checkbox above)	(\$0.00 to \$9.99)					

configuration	account	(6-digit account code if app not connected)				
		(account email if app connected)				
		reset registration (if app connected)	cancel continue			
	dealer	(dealer contact info if entered)				
		remote access	no access monitor adjust settings			
	date & time	month/date/year				
		time				
		use 24-hour time format (checkbox)				
		time zone	(list of North America time zones with radio button selection)			
	messages	service reminders (checkbox)				
		educational messages (checkbox)				
		share alerts with dealer (checkbox)				
		alert history	alert log (if any) clear history (if any)			
	system components	thermostat		device name	main room upstairs downstairs hallway bedroom kitchen other other name (if other selected) (text entry)	
				model ONEPLUS		
				software version (x.x.x format)		
				wifi address (x:x:x:x:x format)		
				thermostat ID (DKN...)		
				restart thermostat	continue cancel	
				outdoor	(outdoor system info if outdoor connected)	
				indoor	(indoor system info if indoor connected)	
		air quality	(list of installed filters)			
		reminders		(list of installed filters with reminders menu for each)	Off	
					1 month	
					2 months	
					3 months	
					4 months	
	6 months					
	12 months					
	restart timer	cancel continue				
	home wifi	use wifi (checkbox)				
		networks (current network)	network list	(password text box if protected)		
show password (checkbox) advanced settings connect				use dhcp (checkbox)		
		searching for networks (or) search again				
dealer edit	cancel					
	continue	(i) 4 digit code (text entry)	(4 digit pin for thermostat)			
		unlock thermostat (or) done	(entry into commissioning screens)			