

DAIKIN ONE+
SETTINGS MENU OUTLINE
 (based on v2.3 software for unitary systems)

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	
system mode	auto (cool & heat)					
	cool					
	heat					
	off					
	emergency heat					
display	language	english				
		español				
		française				
	degree units	fahrenheit				
		celsius				
	brightness	50 - 100% scale				
		night mode		night mode (check box)		
				from (time selection)		
		to (time selection)				
	screen cleaning		touch screen is disabled from screen cleaning (30s)			
use large font (check box)						
use sound (check box)						
use light bar (check box)						
screen saver	off					
	blank screen					
	analog clock					
	digital clock					
lock	Enter a 4-digit PIN...		(number entry)			
schedule	schedule template	basic (awake/sleep)	preview template			
			(contents of template)			
		load template		cancel		
				continue		
		9 to 5 workweek	preview template			
			(contents of template)			
	load template		cancel			
			continue			
	early to rise	preview template				
		(contents of template)				
load template		cancel				
		continue				
manual adjustment overrides	until next event in schedule					
	for one hour					
	for two hours					
	for four hours					
	for eight hours					
away	use geofencing (checkbox)					
comfort	target humidity	humidify if less than (25% - 65%)	(5% increments)			
		dehumidify if more than (35% - 75%)	(5% increments)			
	deadband/overcool	Temperature setpoint deadband: (2°F to 9°F or 1°C to 5°C)	(1°F or 0.5°C increments)			
		Overcooling allowed to dehumidify:	(1°F or 0.5°C increments)			
air quality	circulate air	off				
		always on				
		on a schedule	fan schedule	set times	from (time)	
					to (time)	
	duration		for entire schedule			
			hourly for 5 minutes			
		hourly for 15 minutes				
	hourly for 30 minutes					
	hourly for 45 minutes					
one clean		Off				
		On				
fan speed	low					
	medium					
	high					
utility demand response	program not connected					
	demand response	use demand response (checkbox)				
		When demand response signal is received:	offset temperature setpoints			
			use fixed temperature setpoints			
		response settings	setpoint offsets	Offset heat setpoints by this value: (-1°F to -7°F)		
				Offset cool setpoints by this value: (1°F to 7°F)		
event setpoint limits		(50°F to 90°F)				

			enable energy pricing (checkbox)		
			price trigger (if checkbox above) (\$0.00 to \$9.99)		
configuration	account	(6-digit account code if app not connected)			
		(account email if app connected)			
		reset registration (if app connected)	cancel continue		
	dealer	(dealer contact info if entered)			
		remote access	no access monitor adjust settings		
	date & time	month/date/year			
		time			
		use 24-hour time format (checkbox)			
		time zone	(list of North America time zones with radio button selection)		
	messages	service reminders (checkbox)			
		educational messages (checkbox)			
		share alerts with dealer (checkbox)			
		alert history	alert log (if any) clear history (if any)		
	system components	thermostat	device name	main room	
				upstairs	
				downstairs	
				hallway	
				bedroom	
				kitchen	
				other	
				other name (if other selected)	(text entry)
		model ONEPLUS			
		software version (x.x.x format)			
		wifi address (x:x:x:x:x format)			
		thermostat ID (DKN...)			
		restart thermostat	continue cancel		
		outdoor	(outdoor system info if outdoor connected)		
	indoor	(indoor system info if indoor connected)			
	air quality	filtration			
		HEPA (if added) media electronic (if added) humidifier (if added) dehumidifier (if added)			
	reminders	(list of installed filters with reminders menu for each)	Off		
			1 month		
			2 months		
			3 months		
			4 months		
			6 months		
	12 months				
	restart timer	cancel continue			
	aux heat source (if added)				
home wifi	use wifi (checkbox)				
	networks (current network)	network list	(password text box if protected)		
			show password (checkbox)		
			advanced settings	use dhcp (checkbox)	
			connect		
	searching for networks (or) search again				
	internet connected (check)				
	Daikin One Cloud connected (check)				
	legal notices	terms of use	(text)		
		privacy policy	(text)		
end user license agreement		(text)			
dealer edit	cancel				
	continue	(i)	(4 digit pin for thermostat)		
		4 digit code (text entry) unlock thermostat (or) done	(entry into commissioning screens)		