

Daikin One+ Thermostat Commissioning Menu Outline for Single/multi-split (S21) equipment, v2.7.10 software

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Default	Display only?	Conditions	
welcome	english español française	(radio buttons)				english			
	use large font (checkbox)					unchecked			
	continue								
equipment type	unitary (radio button)	cancel continue				unitary			
	single/multi-split (S21) (radio button)								
	VRV, SkyAir, single/multi-split (P1/P2) (radio button)								
setup	begin setup	(to smart thermostat setup with 5 main steps below)							
	setup options	factory reset							
	learn more	firmware (version #) check for update							
1. Communication	equipment type	unitary				unitary			
		mini/multi-split (S21) VRV, SkyAir, mini/multi-split (P1/P2)							
	wifi	use wifi							
		networks	(list of available networks) search again						Only appears when "use wifi" selected
		internet connected (checkbox)					Yes		Only appears when connected to active wifi network.
		Daikin One Cloud connected (checkbox)					Yes		Only appears if successfully connect to internet.
		legal notices	terms of use (text) privacy policy (text) end user license agreement (text)				Yes Yes Yes		
2. Personalization	language	english español française				english			
	use large font (checkbox)					unchecked			
	date & time	time zone	(list of North America time zones with radio button selection)						set automatically when connect to WiFi.
		month/date/year	(selection with spinner)						set automatically when connect to WiFi.
		hour/minute/am or pm use 24-hour time format (checkbox)	(selection with spinner)				disabled Pacific		set automatically when connect to mobile app.
	name	main room upstairs downstairs hallway bedroom kitchen other (other name)	(text entry for other)				main room		
		degree units	fahrenheit celsius				fahrenheit		
3. Equipment Setup	Indoor Unit: (model #)	Indoor Unit: (model #) (description based on model number)	(pick from list)						
		edit	(text entry)						
		Serial #:	(text entry)						
	Outdoor Unit: (model #)	unit type	wall-mount ceiling cassette single-flow cassette floor-mount					Maybe	Set automatically when model number selected from list. Default allows manual entry, also allowed if manually entered model number.
		Outdoor Unit: (model #) (description based on model number)	(pick from list)						
	Standard filter	Serial #	(text entry)						
		Number of filters	1, 2				1		
	Add Equipment	Remove equipment	Do you want to remove this equipment?	Yes/No					
		air quality sensor Aux heat source Filter box HEPA filter							Can only add 1 of each type.
	Aux heat source	Indoor air quality sensor	Remove equipment	Do you want to remove this equipment?	Cancel Continue				
		Connection	Aux1 Aux2						
			Heat Pump is primary heat source	Control	Heat pump lockout	Heat pump lockout enable (checkbox) -20°F to 65°F in 5°F steps (-27.5°C to 17.5°C in 2.5°C steps)	disabled 15°F (-10°C)		If aux heater added. The HP lockout must be at least 10°F < aux heat lockout.
		Aux heat lockout			Aux heat lockout enable (checkbox) -10°F to 75°F in 5°F increments (-22.5°C to 22.5°C in 2.5°C steps)	disabled 50°F (10°C)			
		T on / T off	Control	Turn on temperature differential: -7°F to -3°F in 1°F steps (-4.0°C to -1.5 to in 0.5°C steps)	-3°F (-1.5°C)				
				Turn off temperature differential: -4°F to 1°F in 1°F steps (-2°C to 0.5°C in 0.5°C steps)	1°F (0.5°C)		Must be at least 4°F (2°C) above T on		
Aux is primary heat source		Control	Heat pump lockout	Heat pump lockout enable (checkbox) -20°F to 65°F in 5°F steps (-27.5°C to 17.5°C in 2.5°C steps)	disabled 15°F (-10°C)		If aux heater added. The HP lockout must be at least 10°F < aux heat lockout.		
			Setpoint differential	-9°F, -7°F, -5°F, -4°F, or -2°F (-5°C to -1°C in 1°C steps)	-2°F (-1°C)				
			T on differential	Turn on temperature differential: -1 or -2°F (-0.5 or -1.0°C)	-1°F (-0.5°C)				
			T off differential	Turn off temperature differential: 1°F (0.5°C)	1°F (0.5°C)	Yes			
Remove equipment	Do you want to remove this equipment?	Cancel Continue							
Filter box	Number of filters	1, 2				1		If filter box added.	
	Remove equipment	Do you want to remove this equipment?	Cancel Continue						
HEPA filter	Number of filters	1, 2				1		If HEPA filter added	
	Remove equipment	Do you want to remove this equipment?	Cancel Continue						
4. System Optimization	Error History	(date and time of error) (code - Indoor Unit #) (error description) (minor error code)							
		Clear error history?	Cancel/Continue	Yes/No					
	Calibration	Temperature calibration	-7°F to 7°F in 1°F steps (or) -3.5°C to 3.5°C in 0.5°C steps				0°F		
		Humidity calibration	-15% to 15% in 1% steps				0%		
	Status	Indoor	suction temp therm (on/off)						
			air temp serial com version discharge temperature						Emura only
		Outdoor	heat exchanger temp						Emura only
electric current flow								Emura only	
fan RPM								Emura only	
liquid pipe temp power consumption EEV aperture								Emura only Emura only	
min/max setpoints	57°F to 90°F in 1°F increments				57°F to 90°F		heating: 57 to 86 cooling: 64 to 90		
deadband / overcool	Temperature setpoint dead band: (2°F to 9°F in 1°F steps)				4°F				

5. Preferences	cool/heat	Overcooling allowed to dehumidify: (0, 1, 2, or 3°F)			0°F		
		changeover settings	start timer diff	1, 2, 3, 4°F (0.5, 1, 1.5, 2.0°C)		1°F	
			forced changeover diff	1, 2, 3, 4°F (0.5, 1, 1.5, 2.0°C)		1°F	
			changeover timer	15 to 60 min. in 15 min. steps		15	Timer started on heat-to-cool or cool-to-heat transition so doesn't change modes too quickly. Timer is ignored if forced changeover diff is reached.
	house settings	House size	500 to 10,000 sf in 100 sf steps				
	dealer information	name	(text entry)				
		phone	(text entry)				
		email	(text entry)				
		website	(text entry)				
		message	(text entry)				
	reminders	Standard filter	off, 1, 2, 3, 4, 6, or 12 months			off	if added in "add equipment"
		Filter box	off, 1, 2, 3, 4, 6, or 12 months			off	if added in "add equipment"
		HEPA filter	off, 1, 2, 3, 4, 6, or 12 months			off	if added in "add equipment"
		service reminder	off, 3, 6, or 12 months			off	